

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170802-E490810  
**Report Reference** E490810-20170728  
**Issue Date** 2017-AUGUST-02

**Issued to:** AB-CO PURGE  
320 Creekside Drive  
Amherst NY 14228

**This is to certify that representative samples of** PURGING AND PRESSURIZING CONTROLS AND ACCESSORIES FOR USE IN HAZARDOUS LOCATIONS  
See addendum page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** NFPA 496 - Standard for Purged and Pressurized Enclosures for Electrical Equipment

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170802-E490810  
**Report Reference** E490810-20170728  
**Issue Date** 2017-AUGUST-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USC/CNC Purging and Pressurization Controls, Type Y for use in Class I, Division 1, Groups A, B, C, and D; Class II, Division 1, Groups F and G Hazardous Locations.

Models AFP-01, AFP-02, AFP-03 when assembled with Cat. No. 1950G pressure switch

Purging and Pressurization Controls, Type Y for use in Class I, Division 1, Groups C and D; Class II, Division 1, Groups F and G Hazardous Locations.

Models AFP-01, AFP-02, AFP-03 when assembled with Cat. No. 1950 pressure switch

Purging and Pressurization Controls, Type Z for use in Class I, Division 2, Groups A, B, C, and D; Class II, Division 2 Groups F and G Hazardous Locations.

Models AP-01, AFP-01, AFP-02, AFP-03 when assembled with Cat. No. 1950G pressure switch

Purging and Pressurization Controls, Type Z for use in Class I, Division 2, Groups C and D; Class II, Division 2 Groups F and G Hazardous Locations.

Models AFP-01, AFP-02, AFP-03 when assembled with Cat. No. 1950 pressure switch



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

